

Installation Instructions: Virtus Flood Lights 11489 / 11492 /11495

Date	Revision
21.12.22	1

Read these instructions before installation and retain for future reference

This equipment should be installed by a competent electrician



Important Information


We recommend that luminaires are installed by a qualified electrician ensuring the installation complies with current IEE wiring regulations BS7671:2018 & local building control...


- · BELL will not accept responsibility for any claims arising from a poor installation.
- Do not cover with any insulation.
- Internal & external use.

This product may contain substances that can be hazardous to the environment if not disposed of properly. Electrical and electronic equipment should never be disposed of with general household waste but must be separated for its correct treatment and

Where possible recycle your packaging.







- The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person.
- For type Y attachments:

if the external flexible cable or cord of this luminaire is damaged, it shall be exclusively replaced by the manufacturer or his service agent or a similar qualified person in order to avoid a hazard.

British Electric Lamps Ltd

Unit A Foxbridge Way, Normanton Industrial Estate Normanton, West Yorkshire. WF6 1TN



Installation Instructions: Virtus Flood Lights 11489 / 11492 /11495

 Date
 Revision

 21.12.22
 1

Read these instructions before installation and retain for future reference

This equipment should be installed by a competent electrician



Important Information


We recommend that luminaires are installed by a qualified electrician ensuring the installation complies with current IEE wiring regulations BS7671:2018 & local building control..

- BELL will not accept responsibility for any claims arising from a poor installation.
- Do not cover with any insulation.
- Internal & external use.

This product may contain substances that can be hazardous to the environment if not disposed of properly. Electrical and electronic equipment should never be disposed of with general household waste but must be separated for its correct treatment and recovery.

Where possible recycle your packaging.





Product Specifications	200W	300W
Input Voltage	220 - 240VAC	
Power Frequency	50/60 Hz	
Outlook Dimensions	447x359x75mm(17.60"x14.13"x2.95")	495x419x75mm(19.49"x16.49"x2.95")
Luminaire Net Weight	5.2±0.3kg(11.46±0.66Lbs)	6.4±0.3kg(14.11±0.66Lbs)
Projected Area	0.112m²(1.205ft²)	0.144m²(1.554ft²)
Working Temperature	-30°C to +45°C(-22°F to +113°F)	
Storing Temperature	-40°C to +70°C(-40°F to +158°F)	

British Electric Lamps Ltd

Unit A Foxbridge Way, Normanton Industrial Estate Normanton, West Yorkshire. WF6 1TN

Technical Helpline +44 (0)1924 893380