

We, CQR Security Limited of 125 Pasture Road, Moreton, Merseyside CH46 4TH. United Kingdom

Declare that: Model No: AEM20001/KIT

Description: Deedlock by CQR Slimline 280kg/ 600lbs Single Magnet Un-monitored including ZL bracket

Is in conformity with the applicable requirements of the following standards:

BS EN 16340-1:2014 + A1: 2018 for 30 & 60-minutes on timber doors, fire resistance performance on the exposed side of the door with 2 No. uninsulated vision panels.

Warrington Fire CRM references:

685767 685968

Warrington Fire Test Numbers:

549185 549186

Completed Test Date: Tuesday 14th January 2025

I, the undersigned, hereby declare that the equipment specified above has been designed to meet the requirements of the relevant sections of the above referenced.

Adam Gallacher Name: Position: Product & Marketing Director On: 29th January 2025 Place: Moreton, UK

	R/
Signed	
-0	