



# Certificate of Conformity

We, CQR Security Limited  
of 125 Pasture Road, Moreton, Merseyside CH46 4TH. United Kingdom

Declare that: **Model No:** AEM20002/KIT

**Description:** Deedlock by CQR Slimline 280kg/ 600lbs Single Magnet Monitored including ZL bracket

Is in conformity with the applicable requirements of the following standards:

BS EN 16340-1:2014 + A1: 2018 for 30 & 60-minutes on timber doors, fire resistance performance on the exposed side of the door with 2 No. uninsulated vision panels.

Warrington Fire CRM references:

685767

685968

Warrington Fire Test Numbers:

549185

549186

Completed Test Date: Tuesday 14<sup>th</sup> January 2025

I, the undersigned, hereby declare that the equipment specified above has been designed to meet the requirements of the relevant sections of the above referenced.

Name: Adam Gallacher  
Position: Product & Marketing Director  
On: 29<sup>th</sup> January 2025  
Place: Moreton, UK

Signed