

Nº. CPR-CABS8723HF/GY/100/C

1. Unique identification code of the product-type:

CABS8723HF/GY/100/C

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

2x2c HF twisted pairs 8723 Belden equivalent

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to Article 11(5):

**CQR Security Ltd
125 Pasture Road, Moreton, Merseyside, CH46 4TH United Kingdom
Tel:+44 (0)151 606 1000, e-mail: info@cqr.co.uk**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1+

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

British Approvals Service for Cables (BASEC) NB 2661

8. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Reaction to Fire	Cca, s1a, d0, a1	EN50575:2014 +A1:2016
Dangerous substances	none	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacture identified in point 4.

Signed for and on behalf of the manufacturer by:

Nigel v. Woerdekom
Technical Manager
Moreton, UK
12th January 2024

