Installation Engineers Contact Details:		Luminaire Ref / Location
Name:	Tel:	

Luminaire Details:

Full Recharge Duration 24Hours Duration: 3hrs Lamp Type:

ROUTINE TEST RECORD										
Test Type	Year	· 1	Year 2		Year 3		Year 4		Year 5	
	Signed	Date								
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
Functional										
3hr Duration										

Dimensions:

Part No.	Description	L (mm)	W (mm)	H (mm)	Weight
430967	Grafham E-SEL3 Avon Emergency Conversion Pack 2W Plug & Play	200	43	30	240g

End Of Life Disposal:

Disassembly instructions for end of life disposal available on website.

Disposal of Electronic Equipment WEEE Directive 2002/96/EC This product falls within the scope of the Waste Electrical & Electronic Equipment Directive (WEEE), which means the product should not be disposed of as normal household waste. Please recycle where facilities exist or check with your Local Authority. RoHS - All components and materials used in this product are RoHS 2002/95/EC compliant. Specifications may change from time to time. The information contained in this leaflet is for guidance only and should not be considered as always accurate and should be treated as not representative.



Manby Park, Manby, Louth, Lincolnshire, LN11 8UT Lumineux Group is a trading name of B&T Associates Ltd.

re. proc Rev L1.0 241896



1

Installation Instructions

Grafham Emergency Pack

Input	220-240V AC 50/60Hz	
Power	2W	
Operating Temp	0-60°C	
Battery	3.2V LiFePO4 3200mAh	
Recharge Time	24Hrs	
Function	Self-Test / Manual Test	
Light Source Energy Rating	N/A	

Box Contents:

- Emergency Pack
- Emergency Indicator Bezel


Tools Required For Installation:

20mm Hole Saw











STOP READ THESE INSTRUCTIONS THOROUGHLY BEFORE INSTALLATION KEEP THESE INSTRUCTIONS FOR FUTURE REFERENCE. IMPORTANT: This product must be installed by a qualified electrician or compatent performance.

IMPORTANT: This product must be installed by a qualified electrician or competent person, and in accordance with current building and IET wiring regulations.

Warranty:

This product is warranted for a period of 5 Years from the date of purchase**. The backup battery pack in the emergency version is warranted for a period of 5 Years. The warranty could be invalidated should the product not be installed according to these instructions, outside the scope of the specification or the product has been altered or tampered with in any way. Please see website for terms and conditions.

www.lumineux.co.uk

Technical Helpline: +44(0)1507 328031

WARNING: Risk of electric shock!



Isolate the mains power before proceeding.

Turn off the mains power before performing inspections, installation, or removal
Verify that the supply voltage is correct by comparing it with the luminaire label information
It is the installers responsibility to ensure installation is suitable for the total load of the luminaire(s). The supply cable, fuses/circuit brakers must be correctly rated for the electrical load and considering for any transient inrush currents that may occur.

• Do not perform insulation strength or resistance tests on installed luminaire(s) connected

Wiring instructions for units equipped with EMERGENCY function:

Emergency lighting luminaires must be installed and maintained in accordance with the emergency lighting standard BS 5266-1

- For the emergency unit to work correctly, please ensure that an uninterrupted permanent live feed is present and is connected directly to the 'Permanent Live' terminal of the mains terminal block. Please ensure there are no switches, PIRs etc within the permanent live feed, constant switching of the emergency pack could result in premature battery failure.
- Following power up the green LED indicator should illuminate to indicate charging. If power to the unit is disrupted or isolated, the unit indicating green LED will switch off, triggering the emergency LEDs to illuminate.
- When self-test mode is selected, 24hrs from connection to mains power, a 3hrs duration test will be performed automatically.

Installation Procedure:

- 1. Connect the emergency pack output cable to LED driver input terminals as shown.
- 2. Wire emergency pack AC input cable to mains as shown.
- 3. Install the light fitting and emergency pack into desired location.
- 4. Install the emergency LED indicator into the bezel first, then install the bezel into desired hole (recommended hole size for bezel is 20mm diameter).
- 5. Reconnect mains supply. Light fitting should turn ON and green LED indicator on the pack should flash slowly.

*The light will perform automatic duration test after 24hours of being powered ON. **To reset an failure error unplug the battery, Power ON, plug the battery in, green LED should come ON.

Emergency Indication:

	Colour	LED Indication	Status
	Green	Permanent Green	Normal Function
	Green	Slow Flashing Green (3 sec on, 1 sec off)	Charging Mode
- <u>)</u>	Green	Slow Flashing Green (1 sec on, 1 sec off)	Duration Test In Progress
. 1.	Green	Fast Flashing Green (0.1 sec on, 0.1 sec off)	Function Test In Progress
342	Red	Permanent Red	Load Failure
1	Red	Slow Flashing Red (1 sec on, 1 sec off)	Battery Failure

