



CERTIFICATE OF APPROVAL

No CF 6006

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

RUTLAND UK
WHITTINGTON WAY
CHESTERFIELD
UNITED KINGDOM
S41 9AG
TEL: 01246 261491

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**TS.11204 & TS.11205 Surface
Mounted Overhead Closers**

TECHNICAL SCHEDULE

**TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued:
Reissued:
Valid to:

6th September 2021
3rd September 2026
5th December 2026





CERTIFICATE No CF 6006 RUTLAND UK

TS.11204 & TS.11205 SURFACE MOUNTED OVERHEAD DOOR CLOSERS

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the following overhead mounted door closing devices and configurations:

TABLE 1						
Link-arms			Slide arms			
Projecting arm (Fig. 1) <i>Body door mounted on pull face</i>	Projecting arm (Fig. 61) <i>Body transom mounted on push face</i>	Parallel arm (Fig. 6) <i>Body door mounted on push face</i>	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
TS.11204	✗	✗	✓	✗	✓	✗
TS.11205	✗	✗	✓	✗	✓	✗

Key: ✓ - approved ✗ - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

3. This approval relates to their use with the following door assemblies: -
Code ITT - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.
4. The closers are approved on the basis of:
 - i) Initial type testing to BS EN 1154 and BS EN 1634-1
 - ii) An appraisal against TS34
 - iii) Certification of quality management system.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers when mounted in the applications stated later under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1:2014+A1:2018 or BS 476-22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Signed Page 2 of 6
J/150

Issued: 6th September 2021
Reissued: 3rd September 2026
Valid to: 5th December 2026



CERTIFICATE No CF 6006

RUTLAND UK

TS.11204 & TS.11205 SURFACE MOUNTED OVERHEAD DOOR CLOSERS

6. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
7. Where the closers are fitted to door leaves or frames that are manufactured from mineral-based materials, or low-density cellulosic-based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
8. Timber based doorset shall be installed in accordance with BS 8214.
9. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed Page 3 of 6
J/150

Issued: 6th September 2021
Reissued: 3rd September 2026
Valid to: 5th December 2026



CERTIFICATE No CF 6006 RUTLAND UK

TS.11204 & TS.11205 SURFACE MOUNTED OVERHEAD DOOR CLOSERS

7. The following table show acceptable doorset types and fire resistance periods:

TABLE 2				
	Approved Door Type			
Class	IMM	MM	ITT	ITM
FD20	x	x	✓	x
FD30	x	x	✓	x
FD60	x	x	✓	x
FD90	x	x	✓	x
FD120	x	x	✓	x
FD240	x	x	x	x
E 20	x	x	✓	x
EI 20	x	x	✓	x
E 30	x	x	✓	x
EI 30	x	x	✓	x
E 60	x	x	✓	x
EI 60	x	x	✓	x
E 90	x	x	✓	x
EI 90	x	x	✓	x
E 120	x	x	✓	x
EI 120	x	x	✓	x
E 240	x	x	x	x
EI 240	x	x	x	x

Key:

- ✓ - Approved
- x - Not approved

Signed Page 4 of 6
J/150

Issued: 6th September 2021
Reissued: 3rd September 2026
Valid to: 5th December 2026



CERTIFICATE No CF 6006

RUTLAND UK

TS.11204 & TS.11205 SURFACE MOUNTED OVERHEAD DOOR CLOSERS

8. Doors are classified as the following types:

Code ITT - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code ITM - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in steel frames.

Code MM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Classification codes:

TS.11204 body door mounted pull face and body door mounted push face (EN1154):

3	8	4 2	1	1	3
---	---	--------	---	---	---

TS.11205 body door mounted pull face and body door mounted push face (EN1154):

3	8	5 2	1	1	3
---	---	--------	---	---	---

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body.
- The closers may not be fitted to timber doorsets without perimeter intumescent fire seals to the frame rebate or door edge.
- Mechanical Hold open option is not approved.

Signed Page 5 of 6
J/150

Issued: 6th September 2021
Reissued: 3rd September 2026
Valid to: 5th December 2026



CERTIFICATE No CF 6006

RUTLAND UK

TS.11204 & TS.11205 SURFACE MOUNTED OVERHEAD DOOR CLOSERS

Scope of Approval:

- The following functions are supported by this certification:

TABLE 3				
Closer Ref.	Application	Latch Control	Backcheck	Delayed-Action
TS.11204	Body door mounted on pull face	Yes	No	No
TS.11204	Body door mounted on push face	Yes	No	No
TS.11205	Body door mounted on pull face	Yes	No	No
TS.11205	Body door mounted on push face	Yes	No	No

Further Information

Further information regarding the details contained in this certificate may be obtained from Rutland UK (Tel: 01246 261491).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed Page 6 of 6
J/150

Issued: 6th September 2021
Reissued: 3rd September 2026
Valid to: 5th December 2026